



Electrical Load Tabulation ILC-Americas

SLAC
Sept 7, 2006

John Santic
Fermilab



Electrical Power Distribution Systems

Defined as

“RF”

“Conventional”

“Emergency”



RF Power

Includes:

Modulators/Klystrons



Conventional Power

Includes:

- Lighting (Non-Emergency)
- NC Magnets
- Water Systems
- Cryo Systems
- Non Life-Safety related HVAC



Emergency Power

Includes:

Emergency Lighting

Sump Pumps

Supply and Exhaust Ventilation Systems

Fire Alarm Systems

All Emergency Systems normally powered via Conventional Power System with Generator Backup



BASIS OF TABULATION

- All Loads Considered **PRELIMINARY**.
- All Values In Watts, kiloWatts or Megawatts as noted.
- No Place Holders from Previous Spreadsheets Carried Over (2001/2003).
- Tabulation Revised as Input is Made Available (Constant Process).



BASIS OF TABULATION

- Tabulation developed for Machine Operating timeframe.
- Valid only for 2 Tunnel Design (Full Power Machine).
- No diversity included for any calculations (Diversity is not required for RF or technical loads).
- Losses in power distribution system and motor efficiency not included or accounted for.
- Brake Horsepower for rotating loads utilized when provided.
- 20°F delta values utilized for water system values.



SLAC vs Vancouver

MAJOR CHANGES

| | <u>SLAC</u> | <u>VANCOUVER</u> | <u>NET</u> |
|------------------|-------------|------------------|------------|
| | MW | MW | MW |
| RF | 133.2 | 115.0 | +18.2 |
| CRYO | 35.0 | 74.3 | -39.3 |
| BDS (NC MAGNETS) | 17.3 | 71.4 | -54.1 |
| OTHERS | | | -9.2 |
| <u>TOTALS</u> | 273.9 | 358.3 | -84.4 |



ELECTRICAL LOAD TABULATION

| AREA SYSTEM | RF | CONV | NC MAGNETS | WATER SYSTEMS | CYRO | EMER | TOTAL (by Area) | NOTES |
|--------------------------|--------------|-------------|-------------|---------------|-------------|-------------|-----------------|----------------------------|
| SOURCES e- | 17.86 | 0.05 | 3.48 | 1.14 | 0.00 | 1.09 | 23.62 | |
| SOURCES e+ | | 0.05 | | | | | 1.14 | |
| DR | 14.00 | 0.05 | 14.01 | 1.93 | 3.56 | 6.17 | 39.73 | |
| RTML | 8.40 | 3.29 | 3.22 | 1.42 | 2.48 | 1.68 | 20.51 | |
| MAIN LINAC | 92.98 | 22.33 | 1.41 | 13.21 | 28.70 | 3.29 | 161.92 | |
| BDS | 0.00 | 0.03 | 17.30 | 0.00 | 0.24 | 0.29 | 17.86 | 14mr Values for NC Magnets |
| DUMPS | 0.00 | 3.23 | 0.00 | 3.74 | 0.00 | 2.20 | 9.17 | |
| TOTAL (by System) | 133.2 | 29.0 | 39.4 | 21.5 | 35.0 | 15.8 | | |

273.9 MW

History

| | | | | | | | | |
|-----------|-------|------|------|-------|------|------|-------|----|
| SLAC | 133.2 | 29.0 | 39.4 | 21.5 | 35.0 | 15.8 | 273.9 | MW |
| Vancouver | 115.0 | | | 227.5 | | 15.8 | 358.3 | MW |